



KARNATAKA GOVERNMENT

TALUK HEALTH OFFICE BANGALORE EAST TALUK K R PURAM BANGALORE

PHONE NO-:080-25612400

E MAIL ID - thobangaloreeast2@gmail.com

REF: THO/NO:281/2025-26

DATE: 19-02-2026

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.**

It is certified that an inspection team headed by **Dr. BB RAGHUNATH I/C Taluk Health Officer** From Taluk Health Office, Bangalore East Taluk, Bangalore Urban District. Health and family welfare Department inspected the **THE GOOD SHEPHERD'S SCHOOL, SY NO. 86/1, BYAPPANAHALLI VILLAGE, BIDARAHALLI HOBLI, BANGALORE EAST TALUK, BANGALORE - 560049, on 19-02-2026** checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above is valid for period a of One Year.

Signature : Dr. B B RAGHUNATH

Designation : TALUK HEALTH OFFICER

To,

THE CHAIRMAN/ Principal
THE GOOD SHEPHERD'S SCHOOL
SY NO. 86/1, BYAPPANAHALLI VILLAGE,
BIDARAHALLI HOBLI, BANGALORE EAST TALUK,
BANGALORE - 560049.

TALUK HEALTH OFFICE
East taluk, K.R. Puram
Bangalore Urban District

Report of Bacteriological analysis of Water Sample

Date: 22.01.2026.

ECUMENICAL CHARITABLE AND SOCIAL EDUCATIONAL SOCIETY FOUND The Good Shepherd's School, Sy No 86/1, Byappanahalli Village, Bidarbanahalli Hobli, Bengaluru East Taluk, Bengaluru - 560049		Opinion						
Sample No	Source & Particulars of Water Sample	M.P.N Count	Plate Count	D.C. Test	S.P.P	N.S.P.P	N.S.P.P & FC	
H535	RO water	NIL	—	—	SPP	—	—	
Note: M.P.N. Count: Most Potable number of Bacteria Per 100ml of Water D.C Test: Differential Coliform test Plate Count: Plate Count per ml of sample SPP: Water is satisfactory for Potable purpose NSPP: Water is not satisfactory for Drinking purpose NSPP & FC: Water is not satisfactory for Drinking purpose and E. Coli found								

For Joint Director (Labs)
PUBLIC HEALTH INSTITUTE,
Public Health Institute,
Seshadri Road, K.R. Circle,
Bengaluru - 560 001
(PTO)

Office of Joint Director
Public Health
Bengaluru - 560001

Advice: 1. Sample

Need effective chlorination before

2. Sample

Need to avoid possible source of faecal contamination and effective chlorination before use for the purpose of Chlorination. Refer the Annexure enclosed.

STANDARD FOR THE DRINKING WATER

			Presumptive Coliform Count Per 100 ml	E Coli Count Per 100 ml
CLASS 1	Excellent		0	0
CLASS 2	Satisfactory		1-3	10
CLASS 3	Suspicious		4-10	0
CLASS 4	Unsatisfactory		Greater than 10	0.1 or More